



THE NEW YORK BLOWER COMPANY
7660 Quincy Street
Willowbrook, IL 60527-5530

Visit us on the Web: <http://www.nyb.com>
Phone: (800) 208-7918 Email: nyb@nyb.com

GUIDE SPEC
GS-226
June 2007

SPECIFYING PLENUM FANS WITH PLR WHEELS

GENERAL

The fans shall be size _____ single-width single-inlet capable of unhooded operation as designed and manufactured by The New York Blower Company. Fan wheels shall utilize non-overloading flat, single thickness blades in all sizes. Unless otherwise directed, fans shall be in compliance with the layout shown on the drawings.

PERFORMANCE

Fan ratings shall be based on tests made in accordance with AMCA Standard 210 in an accredited AMCA laboratory. Fans shall have a sharply rising pressure characteristic extending throughout the operating range to assure quiet and stable operation. Fan brake horsepower shall be equal to or less than _____ BHP at _____ inches static pressure and _____ CFM at _____ density.

SOUND

Fan manufacturers shall provide sound power level ratings for fans tested and rated in accordance with AMCA Standards 300 and 301. Tests shall be performed in an accredited AMCA laboratory. Sound power ratings shall be in decibels (reference 10^{-12} watts) in eight octave bands. Sound power levels will be corrected for installation by the specifying engineer...dBA levels only are not acceptable.

CONSTRUCTION

Fan structure to be fully assembled, heavy gauge construction with integral mounting panel for inlet cone. Unassembled units are not acceptable. Inlet cones shall be aerodynamically designed and spun providing a minimum separation of air flow. Wheel diameters shall be in accordance with the standard dimensions adopted by AMCA for centrifugal fans.

BEARINGS

Bearings are to be grease lubricated, precision anti-friction, self-aligning, foot-mounted pillow block design. Flange mount bearings are not acceptable. Bearings shall be selected for an average minimum L-10 life of 40,000 hours (200,000 hour L-50 life) when rated at the fan's maximum cataloged operating speed.

SHAFT

Shafts are to be ASTM A-108 steel, grade 1040/1045, precision turned, ground and polished. Grade 1018 steel is not acceptable. The shaft's first critical speed shall be at least 120% of the fan's maximum operating speed. The drive end of the fan shaft shall be counter-sunk for tachometer readings.

PAINT

All fan surfaces are to be thoroughly prepared prior to painting using a combination of high pressure chemical wash and hand and power tool cleaning as required. After cleaning, all surfaces are to be coated with an industrial grade, finish coating. Surfaces of bolted components not accessible after assembly shall be coated and allowed to dry prior to final assembly. Primer only will not be accepted.

BALANCE AND RUN TEST

All fan wheels shall be dynamically balanced on precision balancers. Prior to shipment, completed fans shall receive a final test balance at the specified operating speed.

ACCESSORIES

Accessories shall be provided as listed in the plans and specifications.

Required accessories include:

- Internal Inlet-Vane Damper
- Safety Equipment - Belt Guard with Tachometer Opening and Plug - Screen Enclosure - Inlet Guard
- Unitary Base
- Isolation Base - Spring - Rubber-In-Shear
- Drive - Variable V-Belt - Constant V-Belt
- Inlet Collar
- Extended Bearing Lubrication Lines
- Narrow-Width Construction
- Integral Motor Mounting Structure (Arrangement 3-V only)

FINAL INSPECTION

All fans shall receive a final inspection by a qualified inspector prior to shipment. Inspection to include: fan description and accessories, balance, welding, dimensions, bearings, duct and base connection points, paint finish and overall workmanship.

© Registered Trademark of The New York Blower Company